

639.03

43 **(3) Backfilling.** After setting curb or gutter, fill remaining
44 excavated areas with material acceptable to Engineer. Place and
45 tamp material, acceptable to Engineer, in layers up to 6 inches in
46 depth. Do not backfill until 24 hours after constructing joints.

47

48

(B) Asphalt Curb.

49

50

(1) Surface Preparation. Clean fresh laid asphalt surfaces before
51 placing curb. Clean other existing surfaces with compressed air and
52 dry surface.

53

54

Apply tack coat, in accordance with Section 407 – Tack Coat,
55 at rate of 0.05 to 0.15 gallon per square yard of surface, and allow to
56 cure before placing curb. Prevent spread of tack coat beyond area of
57 curb.

58

59

(2) Placing. Construct asphalt curb with self-propelled automatic
60 curb machine, or paver with curbing attachments that conform to the
61 following:

62

63

(a) Machine weight compacts without riding above bed.

64

65

(b) Machine forms curbs of uniform texture, shape, and
66 density.

67

68

(3) Painting and Sealing. Paint or seal curbs in accordance with
69 manufacturer's recommendations.

70

71

(C) Asphalt Gutter.

72

73

(1) Weed Killer. After completing grading and compacting
74 operations, cover subgrade with weed killer in accordance with
75 manufacturer's recommendations.

76

77

(2) Prime Coat. Apply and protect prime coat in accordance with
78 Section 408 – Prime Coat.

79

80

(3) Placing. Place and compact asphalt material in accordance
81 with Section 401 – Hot Mix Asphalt (HMA) Pavement, and as follows:
82 For material placed on a two horizontal to one vertical (2H:1V) slope,
83 compact mixture to relative density of not less than 80 percent of
84 laboratory-compacted density using ASTM D 1561. Finish surface of
85 2H:1V slopes to be uniform in texture, without ruts, corrugations or
86 other irregularities.

87

88

639.04 Measurement. Curb and gutter will be paid on a lump sum basis.
89 Measurement for payment will not apply.

90
91 **639.05 Payment.** Engineer will pay for accepted curb and gutter on a contract
92 lump sum basis. Payment will be full compensation for work prescribed in this
93 section and contract documents.

94
95 Engineer will pay for following pay items when included in proposal schedule:

96	Pay Item	Pay Unit
97		
98		
99	Curb, Type 6	Lump Sum
100		
101	Gutter, Type 7	Lump Sum

102
103
104
105

END OF SECTION 639