

DEPARTMENT OF TRANSPORTATION

Amendment and Compilation of Chapter 19-37
Hawaii Administrative Rules

May 8, 2025

SUMMARY

1. §19-37-2 is amended.
2. §§19-37-5 to 19-37-6 are amended.
3. §§19-37-8 to 19-37-10 are amended.
4. §§19-37-12 to 19-37-14 are amended.
5. §§19-37-18 to 19-37-23 are amended.
6. Exhibit 1 is amended.
7. Exhibit A is amended.
8. Chapter 19-37 is compiled.

HAWAII ADMINISTRATIVE RULES

TITLE 19

DEPARTMENT OF TRANSPORTATION

SUBTITLE 2

AIRPORTS DIVISION

CHAPTER 37

FUEL HANDLING PROCEDURES AT PUBLIC AIRPORTS

\$19-37-1	Purpose
\$19-37-2	Definitions
\$19-37-3	Safety procedures
\$19-37-4	Bonding
\$19-37-5	Fueling operations
\$19-37-6	Overflow or spillage
\$19-37-7	Fire-Aircraft crash
\$19-37-8	Aircraft fuel servicing vehicles
\$19-37-9	Fire extinguishers
\$19-37-10	Marking of aircraft fuel servicing vehicles
\$19-37-11	Leaking vehicles
\$19-37-12	Parking aircraft fuel servicing vehicles
\$19-37-13	Fuel storage tanks
\$19-37-14	Hot refueling procedures for helicopters
\$19-37-15	Application of flammable or combustible finishes
\$19-37-16	Drip pans
\$19-37-17	Protection of hose
\$19-37-18	Transferring fuel
\$19-37-19	Handling, refueling and storing of fuel, lubricants and oxygen
\$19- 37-20	Personnel requirements
\$19-37-21	Director's authority
\$19-37-22	Reporting requirements
\$19-37-23	Penalty
\$19-37-24	Severability

§19-37-1 Purpose. The purpose of this chapter is to establish safe and orderly aircraft fueling operations at public airports in the State of Hawaii. [Eff 2/26/93; comp JUL -5 2025] (Auth: HRS §261-12) (Imp: HRS §261-12)

§19-37-2 Definitions. Unless the context clearly indicates otherwise, as used in this chapter:

"Aircraft" means any and all airplanes, airships, dirigibles, helicopters, gliders, amphibians and seaplanes and any other contrivances now or hereafter used for the navigation of or flight in air space.

"Department" means the department of transportation of the State.

"Director" means the director of the department of transportation or the Director's duly authorized representative.

"FAA" means the Federal Aviation Administration.

"Fuel Handling" means the transporting, delivering, storing, fueling, and draining of fuels or other petroleum products.

"Hot Refueling" means the loading of fuel into a helicopter when one or more of its engines are in operation.

"NFPA" means National Fire Prevention Association.

"Operations Area" or "Airport Operational Area" means any portion of a public airport from which access by the public is prohibited by fences or appropriate signs, and which is not leased or demised to anyone for exclusive use and includes runways, taxiways, all ramps, cargo ramps, and apron areas, aircraft parking and storage areas, fuel storage areas, maintenance areas, and any area of a public airport used or intended to be used for landing, takeoff, surface maneuvering of aircraft or used for embarkation or debarkation of passengers.

"Person" means any individual, firm, partnership, co-partnership, corporation, trust, association, company, joint venture, or legal entity (including any assignee, receiver, trustee or similar representative thereof) or the United States of America or any state or political

subdivision thereof, or any foreign government, or the United Nations.

"Public Airport" means any areas of land or water under public or governmental ownership or jurisdiction which is used, or intended for use, for the landing and taking-off of aircraft and any appurtenant areas which are used, or intended for use, for airport buildings or other airport facilities or rights-of way, together with all airport buildings and facilities located thereon; provided, that federally owned facilities shall be included in this definition only to the extent of their use by non-military persons who hold a contract, lease, license, or other right granted by the department. [Eff 2/26/93; am and comp JUL - 5 2025] (Auth: HRS §261-12) (Imp: HRS §261-12)

§19-37-3 Safety procedures. Fuel handling shall be conducted in compliance with accepted and approved industry safety standards and procedures prescribed in the National Fire Code 407, Aircraft Fuel Servicing, Uniform Fire Code as approved by the State Fire council. [Eff 2/26/93; comp JUL - 5 2025] (Auth: HRS §261-12) (Imp: HRS §261-12)

§19-37-4 Bonding. Prior to making any fueling connection to the aircraft, the fueling equipment shall be bonded to the aircraft by use of a cable, thus providing a conductive path to equalize potential between the fueling equipment and aircraft. The bond shall be maintained until fueling equipment connections have been removed, thus permitting the reuniting of separated charges that could be generated during the fueling operation.

- (1) In addition to the above, when fueling overwing, the nozzle shall be bonded with a nozzle bond cable having a clip or plug to a metallic component to the aircraft that is metallically connected to the tank filler port. The bond connection shall be made before the filler cap is removed. If there is no plug receptacle or means

for attaching a clip, the operator shall touch the filler cap with the nozzle spout before removing the cap so as to equalize the potential between the nozzle and the filler port. The spout shall be kept in contact with the filler neck until the fueling is completed.

- (2) When a funnel is used in aircraft fueling, it shall be kept in contact with the filler neck as well as the fueling nozzle spout or the supply container to avoid the possibility of a spark at the fill opening. Only metal funnels shall be used.
- (3) When a hydrant servicer or cart is used for fueling, the hydrant coupler shall be connected to the hydrant system prior to bonding the fuel equipment to the aircraft.
- (4) Bonding and fueling connections shall be disconnected in the reverse order of connection.
- (5) Conductive hose shall be used to prevent electrostatic discharge but shall not be used to accomplish required bonding. [Eff 2/26/93; comp JUL - 5 2025] (Auth: HRS §261-12) (Imp: HRS §261-12)

§19-37-5 Fueling operations. The following requirements shall be met during fueling operations:

- (1) Hose and connections. Fueling or defueling shall be conducted through the use of hoses and connections meeting approved industry and safety standards;
- (2) Distance. Aircraft fuel handling shall be conducted at least fifty feet away from any hanger or building;
- (3) Public protection. Passengers shall not remain in any aircraft being fueled unless:
 - (A) The cabin exit door is open;
 - (B) A cabin attendant is at such door; and

- (C) A passenger ramp or other safety device to assure the rapid debarkation of passengers is in position at the cabin exit door;
- (4) Personnel. Only personnel engaged in fuel handling, or in the maintenance and servicing of the aircraft being fueled, may be within fifty feet of the fuel tanks of such aircraft;
- (5) Smoking. Smoking is prohibited on the Airport Operational Area and within fifty feet of any aircraft during fuel handling;
- (6) Dump valve testing. Aircraft dump valve shall be tested only in the areas designated for this purpose;
- (7) Aircraft engines. No aircraft may be operated within fifty feet of any fueling operation or spill;
- (8) Electrical storms. All fueling operations shall be conducted with caution during an electrical storm. In the event of any electrical storm causing severe disturbances, all fueling operations shall cease. [Eff 2/26/93; comp JUL -5 2025] (Auth: HRS §261-12) (Imp: HRS §261-12)

§19-37-6 Overflow or spillage. Persons engaged in aircraft fuel handling shall exercise diligence and care to prevent overflow or spillage of fuel and to avoid any combustion hazard. If fuel is spilled from fuel service equipment or from aircraft during refueling, fuel servicing shall be immediately discontinued. The refueler responsible for the spill shall immediately contain and remove spilled fuel and prevent runoff into the airport drainage system. The party responsible for the spill will assume all cleanup costs, including reimbursing the State for any costs incurred as a result of any fuel spill containment or cleanup and any repair or restoration of airport facilities damaged by the spill. The airport fire crew shall be notified if a spill is over five gallons and ten feet in any dimension or over fifty square feet in area; continues to flow; or is otherwise a hazard to

persons or property. Failure to report a fuel spill or failure to contain and remove spilled fuel and prevent entry or runoff into the airport drainage system may result in penalties or arrest as specified in sections 261-17 and 261-21, Hawaii Revised Statutes. [Eff 2/26/93; comp JUL -5 2025] (Auth: HRS §261-12) (Imp: HRS §261-12)

§19-37-7 Fire-Aircraft crash. In the event of a fire or an aircraft crash, no fueling operations shall be conducted in the vicinity of such fire or crash. The director shall determine the distance from such fire or crash beyond which fueling operations may be conducted. [Eff 2/26/93; comp JUL -5 2025] (Auth: HRS §261-12) (Imp: HRS §261-12)

§19-37-8 Aircraft fuel servicing vehicles. All aircraft refueling vehicles shall adhere to the following procedures when operating on the Airport Operational Area:

- (1) Top loading of any type of fuel from one refueling vehicle to another is not permitted;
- (2) Transferring fuel from one tank vehicle to another tank vehicle that is connected to and pumping fuel into an aircraft is not permitted;
- (3) Aircraft fuel servicing tank vehicles shall be in compliance with NFPA 385, Standard for Tank Vehicles for Flammable and Combustible Liquids, 2022 Edition;
- (4) Fuel tank vehicles and Hydrant Carts will be inspected by the Director's designee every quarter (January-April-July-October) using the applicable Airport Certification Manual Inspection Form (8/1/2024), in Exhibit #1, located at the end of this chapter;
- (5) Aircraft refueler units shall be attended and operated only by persons instructed in methods of proper use and operation and who are qualified to

use such refueler units in accordance with minimum safety requirements. Each qualified driver operator shall possess a valid state of Hawaii commercial driver's license, except when operating a non-license vehicle, and an Airport Operational Area motor vehicle operator permit. Hydrant cart operators shall meet the same license and permit requirements as qualified driver operators.

- (6) The front wheels of parked aircraft fuel servicing vehicles and hydrant fuel servicing vehicles, shall be chocked front and rear, in addition to the parking brake being locked.
[Eff 2/26/93; am and comp JUL -5 2025] (Auth: HRS §261-12) (Imp: HRS §261-12)

§19-37-9 Fire extinguishers. These requirements apply to all operation, maintenance, and use of aircraft refueler units:

- (1) Each aircraft fuel servicing tank vehicle shall have two listed extinguishers, each having a rating of at least 20B mounted one on each side of the vehicle.
- (2) Each aircraft servicing hydrant vehicle shall have one extinguisher having a rating of at least 20B mounted.
- (3) Extinguishers must be readily accessible from the ground. The area paneling or tank shell adjacent to or immediately behind the extinguisher(s) on fueling vehicles shall be painted with a contrasting color;
- (4) Only dry chemical and halon extinguishing agents are permissible for use on fuel spills.
- (5) Service Stations shall have at least one fire extinguisher with a minimum 20-B:C classification and it shall be so located that no pump or dispenser is more than seventy-five feet from one such extinguisher;
- (6) When the open-hose discharge capacity of the aircraft fueling system is not more than two

hundred gallons per minute, at least two extinguishers having a minimum 20-B:C classification shall be provided.

- (7) When the open-hose discharge capacity of the aircraft fueling system is more than two hundred gallons per minute but not over three hundred and fifty gallons per minute, at least one wheeled extinguisher having a minimum 80-B:C classification and having a minimum capacity of one hundred and twenty-five pounds of agent shall be provided.
- (8) When the open-hose discharge capacity of the aircraft fueling system is more than three hundred and fifty gallons per minute, at least two wheeled extinguishers having a minimum 80-B:C classification each and having a minimum capacity of one hundred and twenty-five pounds of agent each shall be provided.
- (9) Report use. Use of any extinguisher equipment under any circumstances shall be reported to the Fire Chief immediately after use.
[Eff 2/26/93; am and comp JUL -5 2025] (Auth: HRS §261-12) (Imp: HRS §261-12)

§19-37-10 Marking of aircraft fuel servicing vehicles. Each aircraft fuel servicing vehicle shall:

- (1) Have a sign permanently positioned on each side and on the rear of every fuel carrying vehicle identifying the product;
- (2) Have letters at least three inches high of a color contrasting with the background and color of the vehicle;
- (3) Show the word "FLAMMABLE" and the name of the fuel carried, such as "JET FUEL" or "GASOLINE";
- (4) Have a placard 10 3/4" on each side and on the rear of the vehicle in compliance with guidelines on use of placarding in title 49 Code of Federal Regulations Sections 172.500, 172.101, and 172.102;

- (5) Have "EMERGENCY FUEL SHUTOFF" placarded in letters at least two inches (fifty mm) high;
- (6) Show the method of operation by an arrow or by the words "PUSH" or "PULL" as applicable.
[Eff 2/26/93; comp JUL -5 2025] (Auth: HRS §261-12) (Imp: HRS §261-12)

§19-37-11 Leaking vehicles. Leaking vehicles shall be removed from service, defueled, and parked in a safe area approved by the director, until repaired.
[Eff 2/26/93; comp JUL -5 2025] (Auth: HRS §261-12)
(Imp: HRS §261-12)

§19-37-12 Parking aircraft fuel servicing vehicles.
Parking areas shall be arranged to:

- (1) Facilitate dispersal of the vehicle in the event of emergency;
- (2) Provide at least ten feet of clear space between parked vehicles for accessibility for fire control purposes;
- (3) Prevent any leaking fuel from draining to an adjacent building;
- (4) Minimize exposure to damage from out-of-control aircraft;
- (5) Provide at least fifty feet from any airport terminal building; aircraft cargo building; aircraft hanger; or other structure housing the public which has windows or doors in the exposed walls. [Eff 2/26/93; comp JUL -5 2025]
(Auth: HRS §261-12) (Imp: HRS §261- 12)

§19-37-13 Fuel storage tanks. Fuel storage tanks shall conform to the applicable requirements of Underwriters Laboratories (UL Standard 1709). The tank shall be tested by nationally recognized laboratories. Nationally recognized independent listing or testing

agencies acceptable to the authority having jurisdiction include but are not limited to:

- (1) American Petroleum Institute (API)
- (2) American National Standard Institute , Inc. (ANSI)
- (3) American Society of Mechanical Engineers (ASME)
- (4) American Society for Testing and Materials (ASTM)
- (5) Factory Mutual Systems (FM)
- (6) Underwriters Laboratories, Inc. (America)
- (7) Underwriters Laboratories, Canada

Other nationally recognized testing laboratories may be accepted upon approval of the state Fire Council. [Eff 2/26/93; comp JUL -5 2025] (Auth: HRS §261-12) (Imp: HRS §261-12)

§19-37-14 Hot refueling procedures for helicopter.

Refueling of helicopters with operating engines shall only be permitted:

- (1) In accordance with and observance of procedures established for hot refueling by the Federal Aviation Administration;
- (2) With all passenger(s) off the helicopter and at least 50 feet from helicopter being refueled;
- (3) By persons fully qualified to engage in fuel handling;
- (4) With a helicopter pilot at the flight controls;
- (5) Only after the operator has executed a hold harmless agreement, as provided in Exhibit #2, entitled "Helicopter Hot Refueling Agreement (8/1/2024)", located at the end of this chapter, or such other form as may be acceptable to the Attorney General of the State of Hawaii; and
- (6) No hot refueling is permitted on aircraft with reciprocating engines or which use aviation grade gasoline. [Eff 2/26/93; am and comp JUL -5 2025] (Auth: HRS §261-12) (Imp: HRS §261-12)

§19-37-15 Application of flammable or combustible finishes. The applications of Class I or II liquid finishes shall be done only in locations approved by the Fire Chief. [Eff 2/26/93; comp JUL -5 2025] (Auth: HRS §261-12) (Imp: HRS §261-12)

§19-37-16 Drip pans. Every aircraft hangar shall be equipped and maintained with metal drip pans under the engines of all aircraft stored or parked therein. [Eff 2/26/93; comp JUL -5 2025] (Auth: HRS §261-12) (Imp: HRS §261-12)

§19-37-17 Protection of hose. Fuel transfer hose shall be properly placed on the approved reel or in the compartment provided, or may be stored on top decking of refueler, if proper height rail is provided for security and protection of such equipment before any aircraft refueler unit is moved. Such transfer hose shall not be looped or draped over any part of the refueler unit, except as herein provided, nor shall fuel transfer hose be dragged when such refueler unit is moved from one fueling position to another. [Eff 2/26/93; comp JUL -5 2025] (Auth: HRS §261-12) (Imp: HRS §261-12)

§19-37-18 Transferring fuel. No flammable or combustible liquid shall be dispensed into or removed from the fuel system of an aircraft within any aircraft hangar.

No flammable or combustible liquid shall be dispensed into or removed from a container, tank, vehicle, or aircraft except in a location approved by the Fire Chief. [Eff 2/26/93; am and comp JUL -5 2025] (Auth: HRS §261-12) (Imp: HRS §261-12)

§19-37-19 Handling, refueling and storing of fuel, lubricants and oxygen. Any person or organization involved in storing, dispensing, and otherwise handling fuel, lubricants, and oxygen (other than articles and materials that are, or are intended to be, aircraft cargo) on the airport shall observe NFPA 407 Standard for Aircraft Fuel Servicing, 2022 Edition, for protection against fire and explosion and develop and have established in writing a hazardous material plan which shall cover facilities, handling procedures, and training for all persons engage in fueling operation. It will cover as a minimum:

- (1) Bonding procedures;
- (2) Measures for public protection;
- (3) Control of access to storage areas;
- (4) Fire safety in fuel farms and storage areas; and
- (5) Fire Safety in mobile fuelers; fueling pits and fueling cabinets. [Eff 2/26/93; am and comp JUL -5 2025] (Auth: HRS §261-12) (Imp: HRS §261-12)

§19-31-20 Personnel requirements. All fueling agents operating on the airport will comply with the following NFPA 407 Standard for Aircraft Fuel Servicing, 2022 Edition:

- (1) At least one supervisor with each fueling agent shall have completed an aviation fuel training course in fire safety which is acceptable to the FAA;
- (2) All other employees who fuel aircraft, accepts fuel shipments, or otherwise handle fuel shall have received, at a minimum, on-the-job training in fire safety from the supervisor trained in accordance with paragraph (1) of this section; and
- (3) Familiarization with the fire code of the particular county having jurisdiction in which the public airport is located. [Eff 2/26/93; am and comp JUL -5 2025] (Auth: HRS §261- 12) (Imp: HRS §261-12)

§19-37-21 Director's authority. The Director in cases of flagrant violations, at the Director's sole discretion may cancel, revoke, or modify applicable contracts, leases, agreements, permits, rights, or other privileges to use any public airport. [Eff 2/26/93; am and comp JUL -5 2025] (Auth: HRS §261-12) (Imp: HRS §261-12)

§19-37-22 Reporting requirements. All airport tenant fueling agents shall certify to the Director once a year that all training or requirements prescribed by this section have been accomplished and complied with. [Eff 2/26/93; comp JUL -5 2025] (Auth: HRS §261-12) (Imp: HRS §261-12)


§19-37-23 Penalty. Penalties for violation of this chapter shall be as set forth in section 261-21, Hawaii Revised Statutes. [Eff 2/26/93; am and comp JUL -5 2025] (Auth: HRS §261-12) (Imp: HRS §261-12)

§19-37-24 Severability. The provisions of this chapter are declared to be severable and if any portion or the application thereof to any person or property is held invalid for any reason, the validity of the remainder of this chapter shall not be affected. [Eff 2/26/93; am and comp JUL -5 2025] (Auth: HRS §261-12) (Imp: HRS §261-12)

Amendments to and compilation of chapter 19-37,
Hawaii Administrative Rules, on the Summary Page dated MAY 08 2025
were adopted on MAY 08 2025 following a public hearing held on
after public notice was given in the Honolulu Advertiser,
The Maui News, The Garden Island, and the Hawaii Tribune-
Herald on MAR 13 2025

These rules shall take effect ten days after
filing with the Office of the Lieutenant Governor.


Edwin Sniffen (Apr 29, 2025 12:47 HST)
EDWIN H. SNIFFEN
Director of Transportation


JOSH GREEN, M.D.
Governor
State of Hawaii

Dated: JUNE 25, 2025

APPROVED AS TO FORM:


Deputy Attorney General

JUN 25 2025

Filed

Exhibit #1
Airport Certification Manual Inspection Form
(8/1/2024)

DOT 2-239
(AIR-LF 09/92)

DEPARTMENT OF TRANSPORTATION
AIRPORTS DIVISION
FUEL HANDLING FAR 139.321

Employee Certificate of Training

Airport: _____

I certify that _____, has successfully completed a Fuel Handling Program, which has been approved by the Federal Aviation Administration, in accordance with Chapter 19-37 of Title 19, Hawaii Administrative Rules, entitled "Fuel Handling Procedures at Public Airports".

The training was completed on: ____/____/____.

Trainer's Signature

Position

Company

Address

Telephone Number

Please return this form to the Airport Manager's Office.

ARLF (592)

FUEL FARM FIRE SAFETY INSPECTION REPORT

QUARTERLY

1	2	3	4
---	---	---	---

AIRPORT _____
 TENANT NAME _____
 MANAGER _____
 BUS. PHONE _____
 DATE _____

FOLLOW-UP DATE _____

- | | | |
|--|--|---|
| <input type="checkbox"/> YES <input type="checkbox"/> NO | 1. Fencing/Locks/Signed | RE: AC 150/5230-4 |
| <input type="checkbox"/> YES <input type="checkbox"/> NO | 2. Fuel Dispensers Placarded | RE: AC 150/5230-4 |
| <input type="checkbox"/> YES <input type="checkbox"/> NO | 3. "No Smoking" warning properly posted in fuel farm area | RE: NFPA 407:3-8
RE: AC 150/5230-4 |
| <input type="checkbox"/> YES <input type="checkbox"/> NO | 4. Evidence of Smoking | RE: AC 150/523-4 |
| <input type="checkbox"/> YES <input type="checkbox"/> NO | 5. Ignition Sources | RE: AC 150/5230-4 |
| <input type="checkbox"/> YES <input type="checkbox"/> NO | 6. Fire Extinguishers: Proper size and type (inspected) | RE: NFPA 10
RE: NFPA 407 3-13* |
| <input type="checkbox"/> YES <input type="checkbox"/> NO | 7. Fuel Farm Fueling Standard Operating Procedures | RE: FAR-AC 150/5230-4 |
| <input type="checkbox"/> YES <input type="checkbox"/> NO | 8. Fueling Procedures Observed | RE: AC 150/5230-4 |
| <input type="checkbox"/> YES <input type="checkbox"/> NO | 9. Personnel Safety Training Requirements | RE: AC 150/5230-4 |
| <input type="checkbox"/> YES <input type="checkbox"/> NO | 10. Piping and critical areas free from leaks | RE: NFPA 407:2-4.6
RE: FAR-AC 150/5230-4 |
| <input type="checkbox"/> YES <input type="checkbox"/> NO | 11. Grounding connections & rods in good condition | RE: AC 150/5230-4 |
| <input type="checkbox"/> YES <input type="checkbox"/> NO | 12. Bonding Cable - Loading Station | |
| <input type="checkbox"/> YES <input type="checkbox"/> NO | 13. Fuel System Bonding & Grounded | |
| <input type="checkbox"/> YES <input type="checkbox"/> NO | 14. Fuel hose line | RE: NFPA 407:2-2 |
| <input type="checkbox"/> YES <input type="checkbox"/> NO | Pressure test | RE: NFPA 407:3-16 |
| <input type="checkbox"/> YES <input type="checkbox"/> NO | Hose line condition o.k. | |
| <input type="checkbox"/> YES <input type="checkbox"/> NO | 15. Emergency shut-off system | RE: NFPA 407:2-4.5 |
| <input type="checkbox"/> YES <input type="checkbox"/> NO | Working properly | |
| <input type="checkbox"/> YES <input type="checkbox"/> NO | Placarding of shut-off station proper | RE: NFPA 407:4-12.1 |
| <input type="checkbox"/> YES <input type="checkbox"/> NO | 16. Deadman Control - Loading Station | RE: AC 150/5230-4 |
| <input type="checkbox"/> YES <input type="checkbox"/> NO | 17. Housekeeping | RE: FAR-AC 150/5230-4 |
| <input type="checkbox"/> YES <input type="checkbox"/> NO | 18. Farm area free of weeds, debris and other combustibles | |

COMMENTS _____

ORDER TO COMPLY Failure to comply with the foregoing order before the date of such suspension may render you liable to the penalties of Chapter 19-37 of Title 19, Hawaii Administrative Rules entitled "Fuel Handling Procedures At Public Airports" reads as follows: 19-37-19 Penalty. Penalties for violation of this chapter shall be as set forth in section 201-12 Hawaii Revised Statutes. As such conditions are contrary to law, you are hereby required to correct said conditions immediately upon receipt of this notice. An inspection to determine whether you have complied will be conducted on or before: _____

Inspected: _____ Inspector: _____

AIRCRAFT REFUELING SPOT CHECK

QUARTERLY

1	2	3	4
---	---	---	---

Fuel Vendor: _____ Operator's Name: _____
 Hydrant # _____ Tanker # _____
 Vehicle License: _____ Aircraft No: _____
 Date: ____/____/____ Time: _____ Location: (Gate #) _____
 MO DATE YR
 Airport Inspection Decal # _____ Date: _____ PUC # _____

		PROPER PROCEDURE USED		COMMENTS
		YES	NO	
Wheels Chocked	(NTPA #407, 3-4 & NTPA #77, 4-6.1.6)	___	___	_____
Bonding Procedures	"Static Electricity" (NTPA #407, 2-1.7* & 3-15)	___	___	_____
Deadman Control	(NTPA #407, 2-3.15)	___	___	_____
Emergency Shut-Off	(NTPA #407, 2-3.9 & 3-13)	___	___	_____
Extinguishers	(NTPA #407, 3-12)	___	___	_____
Vehicle Placement	(NTPA #407, 3-16*)	___	___	_____
Hoses (Condition)	(NTPA #407, 2-3.18)	___	___	_____
Placards & Signs	(NTPA #407, 3.7*)	___	___	_____
Electrical Equipment Use	(NTPA #407, 2-3.6)	___	___	_____
Engine Exhaust	(NTPA #407, 2-3.11 & 3-8.5)	___	___	_____
Matches, Lighters, Smoking	(NTPA #407, 3-9)	___	___	_____
Lightning Precautions	(NTPA #407, 3-4.5)	___	___	_____
Disconnection Procedures	(NTPA #407, 3-18 & 3-19)	___	___	_____
Aircraft Fuel Servicing Vehicle Parking		___	___	_____

Operator's Signature: _____

Officer-In-Charge: _____

Station/Shift: _____

ORDER TO COMPLY: Failure to comply with the foregoing order before the date of such compliance may render you liable to the penalties of chapter 19-37 of Title 19, Hawaii Administrative Rules entitled "Fuel Handling Procedures At Public Airports" except as follows: (D-37-3) Penalties for violation of 6th chapter shall be as set forth in section 261-21, Hawaii Revised Statutes. At such compliance any contrary to law, you are hereby requested to correct said conditions immediately upon receipt of this notice. As inspection to determine whether you have complied will be conducted on or before: _____

Respectfully, _____ Lieutenant

EXHIBIT #2

HELICOPTER HOT REFUELING AGREEMENT

(8/1/2024)

THIS AGREEMENT, made and entered into as of the _____ day of _____, 19____ by and between the State of Hawaii, hereinafter referred to as the "State", and _____, hereinafter referred to as the "Operator".

WITNESSETH

WHEREAS, the State owns and operates the _____ Airport located at _____

WHEREAS, the Operator desires to refuel its helicopters while one or more of its engines are in operation at the Airport.

NOW THEREFORE, in consideration of the foregoing and of the mutual promises herein contained, the parties hereby agree as follows:

1. **TERM.** The term of this agreement shall be for a period of _____ years commencing _____ and will be automatically renewed for additional _____ year periods under the same terms and conditions, provided that either party may give thirty (30) days prior written notice to the other party of its intent to cancel this Agreement at the end of the initial term of this Agreement or renewal term thereof.

2. **INDEMNIFICATION.**

- A. The Operator shall indemnify, defend and hold the State and its officers, employees, agents, contractors, subcontractors, licensees, or invitees completely harmless from and against any and all liabilities losses, suits, claims, judgments, fines or demands arising by reason of injury to or death of any person or damage to any property, including all reasonable costs for investigation and defense thereof (including but not limited to attorney fees, court costs, and expert fees), of any nature whatsoever arising out of or incident to this agreement and/or the helicopter, refueling or the acts or omissions of helicopter operator, its officers, agents, employees, contractors, subcontractors, licensees, or invitees, regardless of where the injury, death, or damage may occur, unless such injury, death or damage is caused by the sole negligence of the State.
- B. The State shall give to the Operator reasonable notice of any such claim or action.
- C. The Operator shall use counsel reasonably acceptable to the State in carrying out its obligations hereunder.

3. **CONTINUATION.** The provisions of this agreement shall survive the expiration or early termination of this Agreement.

IN WITNESS WHEREOF, the parties have caused this Agreement to be duly executed as of the day and year first above written by their duly authorized officers.

STATE OF HAWAII

By _____

OPERATOR

By _____

